

**Lycoming County, Pennsylvania Five Shelters RFP –
Questions and Answers Series #1**

Dear Proposer,

Listed below are the answers to the questions received as of 4:00 P.M. EST,
January 29, 2021.

Question 1: In Section 5, Scope of Work/Technical Specifications, III Part A, paragraph S on lighting, IV Part B, paragraph S on lighting, and V Part C, paragraph N on lighting: the light count for LED interior lights would be more in line with eight (8) for a 12' x 20', six (6) for a 12' x 16' and 4 for a 10' x 12' so as not to exceed energy efficiency codes. Is that OK?

Answer 1: Yes.

Question 2: In Section 5, Scope of Work/Technical Specifications, III Part A, paragraph Q on environmental system, IV Part B, paragraph Q on environmental system, and V Part C, paragraph L on environmental system: HVAC for the 12' x 20 and 12' x 16' shelters are 31,200 BTU, which would mean a 36,000 BTU or 3 ton HVAC units. Is that your intention?

Answer 2: Yes.

Question 3: In Section 5, Scope of Work/Technical Specifications, III Part A, paragraph Q on environmental system, IV Part B, paragraph Q on environmental system, and V Part C, paragraph L on environmental system: in lieu of thermostat, do you mean lead lag controller?

Answer 3: Yes.

Question 4: In Section 5, Scope of Work/Technical Specifications, III Part A, paragraph T on cable ladder, IV Part B, paragraph T on cable ladder, and V Part C, paragraph O on cable ladder: for the cable trays on 12'x20' and 12'x16' our interpretation is 46' total linear feet of 18" cable tray, and on a 10'x12' shelter our interpretation is 28' total linear feet of 18" cable tray.

Answer 4: Correct.

Question 5: Commercial grade ionization smoke detectors have been discontinued. Is a photoelectric smoke detector OK?

Answer 5: Yes.

Question 6: The total twist lock count of six (6) 120V 30 Amp and six (6) 240V 30 Amp on the 10' x 12' shelters seems to be in excess of the number of racks that could fit in that 10' x 12' shelter option. Is this the twist lock count you want on the 10' x 12' shelter option?

Answer 6: Yes. The twist lock count is required. Please figure on mounting receptacle housings back-to-back and on minimal spacing if necessary.

Question 7: The convenience outlet count on the 10'x12' of eight (8) seems high. Would you prefer six (6)?

Answer 7: Six receptacles are acceptable for the 10'x12' shelters.

Thank you for participating in this process.

Best Regards,

Terri Nelson

Terri Nelson, PMP
Project Supervisor
MCM Consulting Group, Inc.
2595 Clyde Avenue, Suite 1
State College, PA 16801
814- 206-6370 (Phone)
814-834-4714 (Fax)
TNelson@MCMConsultingGrp.com
www.MCMConsultingGrp.com